



Portable Appliance Test Results

Client Andy Waite
Location 10 Duddon Grove, Hull, HU8 9NX
Test Engineer L. Mitchell
Test Date 07-03-16
Job Number N/A
Items Tested 29
Failures 0
Test Frequency 12 Monthly

Earth Test Earth Tests are measured in Ohms. Any Reading lower than 0.50 Ohms is classed as a pass.

Insulation Test Insulation Tests are measured in MegOhms. A reading of greater than 2 MegOhms is classed as a pass for class II equipment, and greater than 1 MegOhms for class I equipment.

Class II Equipment Class II equipment is denoted by there being no reading in the earth test column.

Visual This denotes that only a visual inspection has taken place and the appliance has not been disconnected from the supply.

Code 1 - Denotes access restricted by client. **Code 2** - Denotes access physically restricted. **Code 3** - Denotes not a standard plug

Code 4 - Denotes critical I.T equipment. **Code 5** - Denotes any other reason which is stated on job sheet

N/A This denotes that the equipment either has no fuse or there is no access to the plug or no earth reading

Sticker Number	Appliance Description	Area	Visual Code	Visual	Date	Earth Test	Ins Test	Fuse Size
A975001	6 Way Extension	10 Duddon Close		Pass	07-03-16	Pass	Pass	13
A975002	Lead	10 Duddon Close		Pass	07-03-16	Pass	Pass	13
A975003	Psu	10 Duddon Close		Pass	07-03-16	N/A	Pass	5
A975004	Light	10 Duddon Close		Pass	07-03-16	Pass	Pass	5
A975005	Lead	10 Duddon Close		Pass	07-03-16	Pass	Pass	5
A975006	Light	10 Duddon Close		Pass	07-03-16	Pass	Pass	5
A975007	Lead	10 Duddon Close		Pass	07-03-16	Pass	Pass	5
A975008	4 Way Extension	10 Duddon Close		Pass	07-03-16	Pass	Pass	13
A975009	A/c Adaptor	10 Duddon Close		Pass	07-03-16	N/A	Pass	N/A
A975010	A/c Adaptor	10 Duddon Close		Pass	07-03-16	N/A	Pass	3
A975011	A/c Adaptor	10 Duddon Close		Pass	07-03-16	N/A	Pass	N/A
A975012	A/c Adaptor	10 Duddon Close		Pass	07-03-16	N/A	Pass	N/A

A975013	Psu	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975014	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975015	4 Way Extension	10 Duddon Close	Pass	07-03-16	Pass	Pass	13
A975016	4 Way Extension	10 Duddon Close	Pass	07-03-16	Pass	Pass	13
A975017	Speakers	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975018	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975019	Laser	10 Duddon Close	Pass	07-03-16	Pass	Pass	5
A975020	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	5
A975021	Laser	10 Duddon Close	Pass	07-03-16	Pass	Pass	5
A975022	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	5
A975023	Light	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975024	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975025	Light	10 Duddon Close	Pass	07-03-16	Pass	Pass	5
A975026	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	5
A975027	Light	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975028	Lead	10 Duddon Close	Pass	07-03-16	Pass	Pass	3
A975029	4 Way Extension	10 Duddon Close	Pass	07-03-16	Pass	Pass	13