



Portable Appliance Test Results

Client Andy Waite
Location 10 Duddon Grove, Hull, HU8 9NX
Test Engineer K.Drewry
Test Date 17-03-17
Job Number 12345
Items Tested 20
Failures 0
Test Frequency 12 Monthly

Earth Test Earth Tests are measured in Ohms. Any Reading lower than 0.50 Ohms is classed as a pass.

Insulation Test Insulation Tests are measured in MegOhms. A reading of greater than 2 MegOhms is classed as a pass for class II equipment, and greater than 1 MegOhms for class I equipment.

Class II Equipment Class II equipment is denoted by there being no reading in the earth test column.

Visual This denotes that only a visual inspection has taken place and the appliance has not been disconnected from the supply.

Code 1 - Denotes access restricted by client. **Code 2** - Denotes access physically restricted. **Code 3** - Denotes not a standard plug

Code 4 - Denotes critical I.T equipment. **Code 5** - Denotes any other reason which is stated on job sheet

N/A This denotes that the equipment either has no fuse or there is no access to the plug or no earth reading

Sticker Number	Appliance Description	Area	Visual Code	Visual	Date	Earth Test	Ins Test	Fuse Size
B691576	A/c Adaptor	10 Duddon Close		Pass	23-03-17	N/A	Pass	N/A
B691577	A/c Adaptor	10 Duddon Close		Pass	23-03-17	N/A	Pass	N/A
B691578	Power Supply	10 Duddon Close		Pass	23-03-17	N/A	Pass	N/A
B691579	Lead	10 Duddon Close		Pass	23-03-17	Pass	Pass	13
B691580	Speaker	10 Duddon Close		Pass	23-03-17	Pass	Pass	13
B691581	Lead	10 Duddon Close		Pass	23-03-17	Pass	Pass	13
B691582	Speaker	10 Duddon Close		Pass	23-03-17	Pass	Pass	13
B691583	Lead	10 Duddon Close		Pass	23-03-17	Pass	Pass	5
B691584	Mix Board	10 Duddon Close		Pass	23-03-17	Pass	Pass	5
B691585	Lead	10 Duddon Close		Pass	23-03-17	Pass	Pass	5
B691586	Light	10 Duddon Close		Pass	23-03-17	Pass	Pass	5
B691551	A/c Adaptor	10 Duddon Close		Pass	23-03-17	N/A	Pass	N/A

B691552	Lead	10 Duddon Close	Pass	23-03-17	Pass	Pass	3
B691553	Psu	10 Duddon Close	Pass	23-03-17	Pass	Pass	3
B691554	4 Way Extension	10 Duddon Close	Pass	23-03-17	Pass	Pass	13
B691555	4 Way Extension	10 Duddon Close	Pass	23-03-17	Pass	Pass	13
B691556	4 Way Extension	10 Duddon Close	Pass	23-03-17	Pass	Pass	13
B691557	6 Way Extension	10 Duddon Close	Pass	23-03-17	Pass	Pass	13
B691558	Lead	10 Duddon Close	Pass	23-03-17	Pass	Pass	13
B691559	Lights	10 Duddon Close	Pass	23-03-17	Pass	Pass	13